



How to Interpret a Water Analysis Report

F 103

Paul D. Robillard, Assistant Professor of Agricultural Engineering
 William E. Sharpe, Professor of Forest Hydrology
 Bryan R. Swistock, Extension Associate

Whether your water causes illness, stains on plumbing, scaly deposits, or a bad taste, a water analysis (see F 105 *Where to Have Your Water Tested*) identifies the problem and enables you to make knowledgeable decisions about water treatment. What is the significance of the parameters listed in the water test report? This fact sheet outlines some of the major parameters you may see on the analysis and assists you in understanding the report.

Features of a Sample Report

Once the lab has completed testing your water, you will receive a report that looks similar to Figure 1. It will contain a list of contaminants tested, the concentrations, and, in some cases, highlight any problem contaminants. An important feature of the report is the **units** used to measure the contaminant level in your water. Milligrams per liter (mg/l) of water are used for substances like metals and nitrates. A milligram per liter is also equal to one part per million (ppm)—that is one part contaminant to one million parts water. About 0.03 of a teaspoon of sugar dissolved in a bathtub of water is an approximation of one ppm. For extremely toxic substances like pesticides, the units used are even smaller. In these cases, parts per billion (ppb) are used. Another unit found on some test reports is that used to measure radon—picocuries per liter. Some values like pH, hardness, conductance, and turbidity are reported in units specific to the test.

In addition to the test results, a lab may make notes on any contaminants that exceeded the PaDEP drinking water standards. For example, in Figure 1 the lab noted that total coliform bacteria and iron both exceeded the standards.

Retain your copy of the report in a safe place as a record of the quality of your water supply. If polluting activities such as mining occur in your area, you may need a record of past water quality to prove that your supply has been damaged.

*** ANALYTICAL LABORATORY REPORT ***		
Client: Client's name	Collected by: KM	
Project: Analytical Laboratory Services	Project Number: CL000001	
Date Collected: 08/28/90	Time Collected: 7:35 am	
Sample Identification: Kitchen Tap	Lab Number: 01000	
Analysis	Results	Units
Total Coliform Bacteria	50	# /100ml
Nitrate-Nitrogen	4.55	mg/l
pH	7.50	units
Iron	0.55	mg/l
Hardness as CaCo3	280	mg/l
Sulfate Sulfur	32.0	mg/l
Chloride	25.4	mg/l
Specific Conductance	344	umhos/cc
<p>On the basis of the above test result(s), this water sample DOES NOT MEET PaDER drinking water standards</p> <p>The following notes apply to this sample:</p> <p>The Total Coliform Bacteria exceeded the max. lev. of 1 colony/100ml. The Iron level exceeded the limit of 0.3 mg/l.</p>		
<p>Submitted by: _____ Laboratory Manager</p>		

Figure 1. A sample water analysis report

Water test parameters

The following tables provide a general guideline to common water quality parameters that *may* appear on your water analysis report. The parameters are divided into three categories: health risk parameters, general indicators, and nuisance parameters. These guidelines are by no means exhaustive. However, they will provide you with acceptable limits and some information about symptoms, sources of the problem and effects. To find out more about how to treat the water or eliminate the contaminant at the source, see related publication F 103 *How to Interpret a Water Analysis Report*. See the end of this publication for information on how to obtain additional publications.

Table 1 *Health Risk Parameters*. The parameters in Table 1 are some common ones that have known health effects. The table lists acceptable limits, potential health effects, and possible uses and sources of the contaminant.

Table 2 *General Water Quality Indicators* are parameters used to indicate the presence of harmful contaminants. Testing for indicators can eliminate costly tests for specific contaminants. Generally, if the indicator is present, the supply may contain the contaminant as well. For example, turbidity or the lack of clarity in a water sample usually indicates that bacteria may be present. The **pH** value is also considered a general water quality indicator. High or low pHs can indicate how corrosive water is. Corrosive water may further indicate that metals like lead or copper are being dissolved in the water as it passes through distribution pipes. Table 2 shows some of the common general indicators.

Table 1: Standards, symptoms, and potential health effects of regulated contaminants.

Contaminant	Acceptable Limit	Sources/Uses	Potential Health Effects at High Concentrations
Atrazine	3ppb or .003 ppm	used as a herbicide; surface or groundwater contamination from agricultural runoff or leaching	heart and liver damage
Benzene	5ppb or .005 ppm	gasoline additive; usually from accidental oil spills, industrial uses, or landfills	blood disorders like aplastic anemia; immune system depression; acute exposure affects central nervous system causing dizziness, headaches; long term exposure increases cancer risks
Lead at tap	0.01 mg/l	used in batteries; lead gasolines and pipe solder; may be leached from brass faucets, lead caulking, lead pipes, and lead soldered joints	nervous disorders and mental impairment, especially in fetuses and infants; kidney damage; blood disorders and hypertension; low birth weights
Nitrates (NO ₃)	10 mg/l (nitrate-N) 45 mg/l (nitrate)	soil by-product of agricultural fertilization; human and animal waste leaching to groundwater	methemoglobinemia (blue baby disease) in infants (birth-6 months); low health threat to children and adults
Total Coliform	<1 coliform/100 ml	possible bacterial or viral contamination from human sewage or animal manure	diarrheal diseases, constant high level exposure can lead to cholera and hepatitis
Radon	300 pCi/l*	naturally occurring gas formed from uranium decay; can seep into well water from surrounding rocks and be released in the air as it leaves the faucet	breathing gas increases chances of lung cancer; may increase risk of stomach, colon and bladder cancers

* Recommended level in water at which remedial action should be taken. No mandatory standards have been set.

Table 2. General water quality indicators.

Indicator	Acceptable Limit	Indication
pH value	6.5 to 8.5	An important overall measure of water quality, pH can alter corrosivity and solubility of contaminants. Low pH will cause pitting of pipes and fixtures or a metallic taste. This may indicate that metals are being dissolved. At high pH, the water will have a slippery feel or a soda taste.
Turbidity	<5 TU	Clarity of sample can indicate contamination.
Total Dissolved Solids (TDS)	500 mg/l	Dissolved minerals like iron or manganese. High TDS also can indicate hardness (scaly deposits) or cause staining, or a salty, bitter taste.

Nuisance contaminants are a third category of contaminants. While these have no adverse health effects, they may make water unpalatable or reduce the effectiveness of soaps and detergents. Some nuisance contaminants also cause staining. Nuisance contaminants may include **iron bacteria**, **hydrogen sulfide**, and **hardness**. Table 3 shows some typical nuisance contaminants you may see on your water analysis report.

Hardness is one contaminant you will also commonly see on the report. Hard water is a purely aesthetic problem that causes soap and scaly deposits in plumbing and decreased cleaning action of soaps and detergents. Hard water can also cause scale buildup in hot water heaters and reduce their effective lifetime. Table 4 will help you interpret the hardness parameters cited on your analysis. Note that the units used in this table differ from those indicated in Figure 1. Hardness can be expressed by either mg/l or a grains per gallon (gpg). A gpg is used exclusively as a hardness unit and equals approximately 17 mg/l or ppm. Most people object to water falling in the "hard" or "very hard" categories in Table 4. However, as with all water treatment, you should carefully consider the advantages and disadvantages to softening before making a purchasing a water softener.

Additional Resources

For more detailed information about water

testing ask for publication *Water Tests: What Do the Numbers Mean?* at your local extension office or from the following sources.

Please access:

Website: <http://wqext.psu.edu>

Email: mxh16@psu.edu

Fax: (814) 863-1031

Phone: (814) 865-7685

For more information about other Outreach Publications and Resources from the Department of Agricultural and Biological Engineering:

Website: <http://www.age.psu.edu>

Email: aqm5@psu.edu

Address: Penn State

246 Agricultural Engineering Bldg.
University Park, PA 16802

Phone: (814) 865-7685

Fax: (814) 863-1031

Table 3. Common nuisance contaminants and their effects.

Contaminant	Acceptable Limit	Effects
Chlorides	250 mg/l	salty or brackish taste; corrosive; blackens and pits stainless steel
Copper (Cu)	1.3 mg/l	blue-green stains on plumbing fixtures; bitter metallic taste
Iron (Fe)	0.3 mg/l	metallic taste; discolored beverages; yellowish stains, stains laundry
Manganese (Mn)	0.05 mg/l or 5 ppb	black stains on fixtures and laundry; bitter taste
Sulfates (SO ₄)	250 mg/l	greasy feel, laxative effect
Iron Bacteria	present	orangeish to brownish slime in water

Table 4. Hardness classifications.

Concentration of hardness minerals in grains per gallon (GPG)	Hardness Level
below 1.0	soft
1.0 to 3.5	slightly hard
3.5 to 7.5	moderately hard
7.5 to 10.5*	hard
10.5 and above	very hard

* level at which most people find hardness objectionable

The Pennsylvania State University is committed to the policy that all persons shall have equal access to programs, facilities, admission, and employment without regard to personal characteristics not related to ability, performance, or qualifications as determined by University policy or by state or federal authorities. It is the policy of the University to maintain an academic and work environment free of discrimination, including harassment. The Pennsylvania State University prohibits discrimination and harassment against any person because of age, ancestry color, disability or handicap, national origin, race, religious creed, sex, sexual orientation, or veteran status. Discrimination or harassment against faculty, staff, or students will not be tolerated at The Pennsylvania State University. Direct all inquiries regarding the nondiscrimination policy to the Affirmative Action Director, The Pennsylvania State University, 201 Willard Building, University Park, PA 16802-2801, Tel 814-865-4700/V, 814-863-1150/TTY.